



Fibershield –/120/120

Fully insulated (-/120/120) single coil fire shutter specification (without sprinkler)

PERFORMANCE REQUIREMENT:

The vertical fire shutter shall be supplied and installed in accordance with AS1905.2:2005 except that the primary means of activation is to be from an AS1670.1:2018 smoke detection system. When fire tested in accordance with Clause 3 Determination of Fire Resistance they shall provide a minimum Fire Resistance Rating (FRR) of -/120/120.

The fire curtains shall resist a pressure differential of no more than 50 Pa.

PRODUCT SPECIFIED

Fibershield 120/120 fire shutter by Smoke Control T: 09 300 1980; info@smokecontrol.co.nz or approved equivalent.

System parameters;

- a) -/120/120 FRR AS1530.4:2014
- b) Smoke leakage (fabric only) : $\leq 25\text{m}^3/\text{hour}$ EN12101-1 (Fabric permeability only). c) Maximum size (opening);
 - i) 6m W x 4.4m H
- d) Deployment speed; nominally 90mm/s
- e) Dimensions
 - i) Headbox;
 - i. Heights up to 4.4m; 460mm H x 430mm W
 - ii) Side Guide;
 - i. 230mm W x 110mm D (headbox extends a further 47mm past outside edge of guide)
- f) Power requirements;
 - i) Sizes up to 4m W, 1 of 240v 10amp GPO, peak current draw 2.1A
 - ii) Sizes up to 6m W, 2 of 240v 10amp GPO, peak current draw 2.1A per controller
- g) Alarm input – 0V nominally closed contacts
- h) Pressure resistance maximum;
 - i) Deploying – 10Pa ii) Deployed; - 50Pa
- i) System weight;
 - i) 125kg/m of system width up to 3m H
 - ii) ii) 150kg/m of system width up to 4m H

Note: for applications where pressure differentials are expected, consideration should be given to the induced loading on the surrounding structure of this pressure to ensure appropriate restraint of the system.

- j) Supporting construction type; Masonry or Concrete only (120/120/120) minimum thickness 175mm.
- k) k) Approved installation configuration
 - i) Headbox;
 - i. Face fixed to the wall
 - ii) Side guides;
 - i. Face fixed to the wall

Ancillary items required;

- l) Control system: Shall allow fail safe operation on receipt of a general building alarm signal and automatic rewind on reset of the alarm from the Fire Indicator Panel (FIP) without the assistance of a technician.
- m) Staged Deployment: Staged deployment shall allow the fire curtain to deploy to 2m above the finished floor level, pause for 30 seconds and then deploy to the floor (other configurations available on request).
- n) Battery back up; Shall be installed to reduce the likelihood of nuisance deployments and allow 5 complete open-close cycles.
- o) Rewind switches (operating $\Delta\text{Pa} = 10\text{Pa}$): shall be installed on both sides/one side of the nominated smoke containment screens. They shall allow the system to rewind no more than 2.1m and redeploy within 20 seconds. (other configurations available on request).

- p) Exclusion Zone Sensors; IRS36 shall be installed in accordance with Smoke Control's recommendations to protect each fire curtain asset during normal building use and significantly increase the likelihood of full deployment when in fire mode.
- q) Sounders and strobes: Shall be installed on (*delete not applicable*) both sides/on the same side as the egress path
- r) Maintenance: All fire curtains shall be listed on the Essential Services Register and shall be maintained by competent technicians in accordance with AS1851:2012 and the manufacturers recommendations

APPLICATIONS

- Protection of openings in fire compartment walls (NCC C3.5)
- Replacement of fire rated walls (NCC C1.1, Spec C1.1)
- Separation of fire compartment where it exceed maximum size or volume (NCC C2)

Note: Some applications listed above may require a Performance Solution to be compliant. Please check with your Certifier prior to specifying this product.

INSTALLATION

Fire Curtains

The fire shutters shall be installed, certified, commissioned and tagged in accordance with AS1905.2 -2005 and this Fire Engineering Report by an ISO9001 Quality Accredited manufacturer.

Threshold

Unless addressed as part of an appropriate performance solution the curtain must deploy onto a fire rated or noncombustible threshold as per requirements of AS1905.2:2005 and AS1530.4:2014. Maximum gap permitted at threshold 25mm.

Fire Rated Bulkheads

System is test directly fixed to a fire rated masonry or concrete wall structure. Top fixing of the shutter is not possible. Minimum wall thickness of 150mm.

COMMISSIONING

Once installed it shall be demonstrated that the system shall fail safe close on loss of power using mains power in combination with battery backup and on the receipt of an alarm signal. On reset of power and the alarm signal the system shall automatically rewind to its standby position without the assistance of an occupant or technician.

The fire curtains shall also be commissioned in conjunction with the building's smoke management system. The smoke management system shall be balanced to operate without adverse effects to the fire curtain. The fire curtains must be tested a minimum of 3 consecutive times on general building alarm without failure.

The building's smoke management system shall not impede the operation of the fire curtain. A time delay of 60 seconds shall be incorporated into the smoke management system before it operates to allow the fire curtain to deploy to its fire mode position without interference. This shall be programmed within the Fire Indicator Panel. Consideration shall be made for the staged deployment of the fire curtain.

Similarly, a time delay of 60 seconds shall be incorporated into the reset of the alarm signal to fire curtain to ensure the smoke management system has ceased operation and the effects of pressure differentials have been dispersed prior to rewind of the curtain.

Certificates of Compliance shall be issued by the sub-contractor in accordance with National Construction Code 2019 A5.2 and A5.3 Evidence of Suitability and AS1905.2:2005 Clause 7 Certification.

All details and approvals are current as of the date displayed. This document supersedes all previous versions.